

Shrachi Centre (5th Floor)  
74B, Acharya Jagadish Chandra Bose Road  
Kolkata – 700 016, West Bengal, India  
CIN: U51909WB1956PTC023037

T : 91 33 22172249 / 40143000 / 22650006 / 22650007  
F : 91 33 22650008  
E : info@mitrask.com  
W : www.mitrask.com

### TEST REPORT

**Name & Address of the Customer :**

**'ALMEGA PAINTS (P) LTD.'**

Mouza - Tulsiberia,  
JL. No.-1, Tulsiberia Road,  
P.S-Uluberia, -711401,  
Dist.-Howrah,W.B.

**Report No. :** EC/1010

**Date :** 11.05.2015

**Sample No. :** 1112

**Sample Description :** Effluent Water


**Sample Mark :** Waste Water taken from  
Discharge Pipe

**Sample Drawn on :** 28.04.2015

**Reference No.& Date:** Job Request Form, dtd- 28.04.2015

### ANALYSIS RESULT

Sl. No.	Test Parameters	Test Method	Limit as per CPCB		Result
			Inland Surface Water	Public sewers	
1.	pH value at 26°C	APHA 20TH edition, 4500H+	5.5 to 9.0	5.5 to 9.0	7.39
2.	Total Suspended Solids in mg/l	APHA 20TH edition, 2540D	100	600	2.2
3.	Biochemical Oxygen Demand (for 3 days at 27°C) in mg/l	IS 3025 (Part 44)- 1993	30	350	11.2
4.	Chemical Oxygen Demand in mg/l	APHA 21st edition, 5220B	250	---	51.6
5.	Oil & Grease in mg/l	APHA 20TH edition, 5520A	10	20	<1.4

Report Prepared by: 

for Mitra S. K. Private Limited



Authorised Signatory